

**NORTHERN MAINE COMMUNITY COLLEGE**  
**24' x 13' LED Indoor Display Panel(s) RFP**  
**Questions & Responses ~~June 25, 2019~~**  
**June 28, 2019**

**Q1. Is it possible to get schematics of the proposed display and the surrounding area?**

R1. The College tentatively plans to post schematics of the gym that will show placement of the video wall by July 2, 2019

**Q2. How high off the ground is the display?**

R2. Approximately 15 feet.

**Q3. How many feet from the audience will the sign be located (closest, furthest and average distance in feet)?**

R3. Distance range from 20 feet to 70 feet, the average distance will be approximately 40 feet.

**Q4. Is there a power source for the LED?**

R4. The College will confirm plans to install wall circuits.

**Q5. Is the display going to be mounted on a wall, pole or sitting flat on the ground?**

R5. Wall mount.

**Q6. What is the distance from the display to the control room and is there hardwiring in place or is wireless communication in place?**

R6. The control room will be below the screen with a preference for hard wired.

**Q7. What content will be played on the video wall (advertising, messaging, video, scoreboard)?**

R7. Content will include predominantly messaging, video and event footage.

**Q8. What will be the power source to the video wall at the wall installation?**

R8. The plan is to add 4 circuits at 20 amps each.

**Q9. Do you have steel ceiling beams at the video wall location for hanging the video wall with custom metal bars to mount the frame to?**

R9. The walls are concrete and there are steel ceiling beams.

**Q10. Can photos be provided of the wall and ceiling location?**

R10. Photos attached with the proposed location for the video wall marked in blue.

.....

June 28, 2019

**Q11. Is it possible to extend that installation completion date another 30 days?**

**R11.** We cannot extend the installation completion date.